

PRE-INSPECTION CHECKLIST

FENCE

	YES	NO
Does the entire pool fence stand at least 1200mm High including gate?	<input type="checkbox"/>	<input type="checkbox"/>
Is any part of the fence a boundary fence?	<input type="checkbox"/>	<input type="checkbox"/>
Are all the fence panels secure?	<input type="checkbox"/>	<input type="checkbox"/>
Are all screws and nails and fixing secure?	<input type="checkbox"/>	<input type="checkbox"/>
Are all climbable horizontal rails at least 900mm apart?	<input type="checkbox"/>	<input type="checkbox"/>
Is the top of my pool fence at least 900mm from the nearest horizontal rail?	<input type="checkbox"/>	<input type="checkbox"/>
Is the gap below the bottom of the fence less than 100mm?	<input type="checkbox"/>	<input type="checkbox"/>
Are any of the fences vertical uprights more than 100mm apart?	<input type="checkbox"/>	<input type="checkbox"/>
When you squeeze the vertical bars, does the gap remain less than 100mm on either side?	<input type="checkbox"/>	<input type="checkbox"/>

GATE

Does your pool gate open outwards and away from the pool?	<input type="checkbox"/>	<input type="checkbox"/>
Is the gate able to open and close freely without getting stuck?	<input type="checkbox"/>	<input type="checkbox"/>
Is there a gap below the bottom of the gate less than 100mm?	<input type="checkbox"/>	<input type="checkbox"/>
Does the gate self close and latch itself from any position?	<input type="checkbox"/>	<input type="checkbox"/>
Is the latch release at least 1500mm above the ground?	<input type="checkbox"/>	<input type="checkbox"/>
There are no items to prop the gate open?	<input type="checkbox"/>	<input type="checkbox"/>
Can the gate be forced open when pulled?	<input type="checkbox"/>	<input type="checkbox"/>

WINDOWS & DOORS

Are there windows that open directly into your pool area?	<input type="checkbox"/>	<input type="checkbox"/>
Are there any doors the permit direct access to the pool area?	<input type="checkbox"/>	<input type="checkbox"/>

CLIMBABLE AREAS

Are here any climbable objects within 900mm of the fence such as; trees, pot plants, furniture?	<input type="checkbox"/>	<input type="checkbox"/>
-------------------------------------------------------------------------------------------------	--------------------------	--------------------------

If you have any questions or concerns at all prior to your pool safety inspections please do not hesitate to contact us on 07 5540 3905. You can also email any items that you feel may be an issue prior to your inspection to info@goliathbuilding.com.au

DISCLAIMER: This checklist has been created to be used a guide to all Goliath Pool Safety Inspections Customers to carry out any minor remedial work prior to the official pool safety inspection. The items included on this checklist are some of the more common issues identified during pool safety inspections. Please note at no time should this checklist be used as a pool safety inspection. All Pool Safety Inspections and Certificates must be obtained by a Licenced Pool Safety Inspector.